

EASYFLEX Flexible Sprinkler Drops Appliance Standards

National Fire Protection Association (NFPA):

- NFPA 13: Standard for the Installation of Sprinkler Systems
- NFPA 13D: Standard for the Installation of Sprinkler Systems in One and Two-Family Dwellings and Manufactured Homes
- NFPA 13R: Standard for Installation of Sprinkler Systems in residential Occupancies up to and including four stories in height
- NFPA 13 Section 9.2.1.3.3.3: No hangers are required for flexible connections as long as the length does not exceed 6ft.

American Society for Testing and Methods (ASTM):

- ASTM C635: Standard specifications for the manufacture, performance, and testing of metal suspension systems for acoustical tile and lay-in panel ceilings
- ASTM C636: Standard practice for installation of metal ceiling suspension systems for acoustical tile and lay-in panels

Factory Mutual (FM), FM Class No, 1637:

• Approved standard for flexible sprinkler hose with threaded end fittings


International Building Code (IBC) Section 1621 / American Society of Civil Engineers (ASCE) 7 9.6.2.6.2 & 9.6.2.6.2.2:

• Flexible Sprinkler Connections are the alternative Solution to install without Seismic Escutcheons(Oops Ring)

Job Name :	Engineer / Architect :
Job Location :	Wholesaler :
Submittal Date :	Contractor:



BRAIDED FLEXIBLE HOSE (Ultra Perfomance) 1-1/4" Braided Flex Drop



- 1. TUBE
- 2. ISOLATION RING
- 3. SEALING GASKET
- 4. NUT
- 5. NIPPLE (1")
- 6. REDUCER
- 7. BRAID
- 8. PRESS RING (INNER)
- 9. PRESS RING (OUTER)

SPECIFICATIONS

Lengths Available	24", 36", 48", 60" and 72"	
Outlet	1/2" or 3/4"	
Hose Type	Braided	

Max. Ambient Temperature Rating	225°F
Max. Working Pressure Rating	225 psig

- * No hangers and seismic escutcheons required
- * Required torque to assemble reducer and nipple with the flexible hose: 50 ft-lb

Hose	Stainless Steel 304
Nut & Nipple	Zinc-Plated Steel
Sealing Gasket / Isolation Ring	EPDM/ NYLON

Minimum Bend Radius	6.5" (FM)* DO NOT bend within 2.52 inches from connection nuts	
Connection —	Inlet	1"NPT
	Outlet	1/2" or 3/4"NPT

FRICTION LOSS DATA EFB UP Series Braided Hose OGSB, TBS Bracket Systems.



Length (in.)	Outlet Connection	K-Factor	Max. Number of 90° Bends	Equivalent Length of 1 in. Schedule 40 Pipe, ft.
24"	1/2"	5.6 / 8.0	1	2.1 / 3.6
	3/4"	8.0 / 14.0	1	3.6 / 3.8
261	1/2"	5.6 / 8.0	2	4.5 / 5.1
36"	3/4"	8.0 / 14.0	2	6/6
48"	1/2"	5.6 / 8.0	3	6.9 / 6.6
	3/4"	8.0 / 14.0	3	8.4 / 8.3
COII	1/2"	5.6 / 8.0	4	9.4 / 8.1
60"	3/4"	8.0 / 14.0	4	10.9 / 10.6
72"	1/2"	5.6 / 8.0	4	11.9 / 9.7
	3/4"	8.0 / 14.0	4	13.4 / 12.9

^{*} FM: 6.5" minimum bend radius, where C=120

